

# Taste Baking Company - Sacramento

## Preventive Maintenance List

Print Date: 6/9/2017

Plant 327

Printed By:

Task:	Interval:	Start	Due	Hours	Parts Used/Comments
-------	-----------	-------	-----	-------	---------------------

### Yeast Refrigeration Compressor #1

S/N: 6734569379

Location: Roof

Manufacturer: Trane

Asset: 21347

Building: A

Model: YT-622

*Use Safety Equipment.*

*Do Not Bypass Safeties.*

*Do Not Operate Equipment Without Guards in Place.*

*Use Proper Lock-Out/Tag-Out.*

<input type="checkbox"/> 1	1,338	Charlie Huston					
Check/Repair Hydraulic Oil Leaks	7	3/30/2011	4/6/2011				

Notes:

Parts Description:	Parts Number:	Quantity Needed:	Available:	Location:
<input type="checkbox"/> ATQR 15, MIDGET TIME DELAY TRANSFORMER FUSE, 15 AMP. 600V., CLASS CC	65757	2 EA	0 No Stock	Parts Stock

<input type="checkbox"/> 2	1,216	Charlie Huston					
Check Sprockets/Replace	7	3/30/2011	4/6/2011				

Notes:

<input type="checkbox"/> 3	934	David Hackworth					
Check Blower Oil Level	30	3/30/2011	4/29/2011				

1. \_\_\_ Lockout tagout the equipment and document.
2. \_\_\_ Remove chain guard(s) and to access fill plug.
3. \_\_\_ Check oil level and ensure it reaches the bttom of the fill plug. Fill as needed with SAE 90W ND.  
Quantity used: \_\_\_\_\_ oz.
4. \_\_\_ Examine oil color, smeel and consistency. Replace oil if out of spec.
5. \_\_\_ Clean area and reassemble. Restore power after auditing job.

Notes:

- Remove Tools and Parts From Area.
- Replace and Secure Guards.
- Check Safeties for Proper Operation.
- Remove Lockout(s) When Safe to Do So.